

Experience of HTTR licensing for Japan's New Nuclear Regulation

Summary / Objectives:

The new **safety theory which used HTTR's inherent safety design and results of safety demonstration test** has been approved by Nuclear Regulation Authority (NRA) . As a result, JAEA obtained permission by NRA toward the restart of the HTTR in conformity to the New Regulatory Requirements on 3rd June 2020. HTTR is expected to be restarted without any additional reinforcement due to its **own high-level inherent safety features**. Following the restart of HTTR, number of activities are planned: **Safety demonstration test** in OECD/NEA LOFC project; **Technology demonstration test of heat utilization system**; International cooperation and human-resource development utilizing the HTTR.


Meet the Presenter:

Dr. Etsuo Ishitsuka is the general manager of the HTTR Reactor Engineering Section at the Department of HTTR project in JAEA. He earned his Doctorate of Engineering from the University of Tokyo in 1999. His current works are the technology developments related to core management and operation. His team was in charge of the seismic evaluation of facilities and beyond design basis accidents in this licensing.




1. New regulatory requirements for HTTR

Comparing with the old regulatory standards, the new regulatory standards for HTTR are explained.



2. Towards the restart of HTTR

The activities towards the restart of HTTR on licensing are summarized.



3. Safety requirements

Comparison of safety requirements between Modular HTGRs and LWRs is shown.


Safety requirements

| Safety requirements | | Modular HTGRs | LWRs |
|--------------------------------------|--------------------|---|---|
| Design extension condition (DEC) | | <u>DEC without significant fuel degradation</u> | DEC without significant fuel degradation DEC with core melting |
| Reactor shutdown | | At least two diverse and independent means (Inherent design features is regarded as one of means) | At least two diverse and independent systems |
| Heat removal from core | | Passive cooling from the outside surface of reactor vessel (Passive cooling) | In shutdown states: Residual heat removal (Forced cooling) In accident condition : Emergency core cooling (Forced cooling) |
| Confinement of radioactive materials | Fuel integrity | In operational states and in accident conditions | In operational states (normal operation and AOO) |
| | Containment system | Confinement (i.e., vented low-pressure containment) | Containment Vessel |
| Additional specific considerations | | Mitigation of air and water ingress into core during accidents | - |

4. Safety importance classification

Unique classification of the HTTR different from the NPP was proposed to the NRA by explaining the inherent safety design and results of safety demonstration tests.

Safety importance classification



5. HTTR safety review results by NRA (1/2)

The results of HTTR safety review by NRA related to earthquake, tsunami and SSCs integrity are explained.

GEN IV International Forum



HTTR safety review results by Nuclear Regulation Authority (1/2)

| Major discussion item | | Regulatory review condition | Regulatory review results | Additional countermeasures |
|--|--|---|---|-------------------------------|
| Earthquake | Design seismic ground motion | Raised from 350 gal to 973 gal | No large-scale reinforcement due to the degradation of the SSCs. | Not required |
| | Re-evaluation of seismic design classification | <p>Some of structures, systems and components (SSCs) were downgraded taken into account the results of safety demonstration tests.</p> <ul style="list-style-type: none"> ➢ Core heat removal: S class to B class ➢ Reactor internal structure: S class to B class. | | |
| Tsunami evaluation | | Assumption of tsunami height for evaluation : 17.8 m from sea level | Tsunami does not reach the site because siting location is 36.5 m high from the sea level. | Not required |
| Evaluation of integrity of SSCs against natural phenomena such as tornado, volcano, etc. | | <ul style="list-style-type: none"> ● Design basis tornado wind speed: 100 m/s ● Thickness of descent pyroclastic material by volcano: 50 cm | <ul style="list-style-type: none"> ● All SSCs needed to be protected are installed inside the reactor building ● Fire proof belt necessary around reactor building. | Fire proof belt was required. |

6. HTTR safety review results by NRA (2/2)

The results of HTTR safety review by NRA related to fire, reliability of power supply and BDBA are explained. HTTR will restart without significant additional reinforcements due to its inherent safety features.

GEN IV International Forum



HTTR safety review results by Nuclear Regulation Authority (2/2)

| Major discussion item | Regulatory review condition | Regulatory review results | Additional countermeasures |
|-------------------------------------|---|---|---|
| Fire | Burnable materials in and around the reactor building was additionally evaluated. | <ul style="list-style-type: none"> ● Amount of burnable materials in the reactor building is limited. ● Cables necessary to be protected against fire | Cable protection against fire was required. |
| Reliability of power supply | Emergency power supply failure was evaluated. | Decay heat is removable from the core without electricity. | Only portable power generator for monitoring during accident is required. |
| Beyond design basis accident (BDBA) | <p>Postulated BDBAs</p> <ul style="list-style-type: none"> ➢ DBA + failure of reactor scram ➢ DBA + failure of heat removal from the core ➢ DBA + failure of containment vessel <p>(DBA : Design Basis Accident)</p> | <ul style="list-style-type: none"> ● No core melt occurs in all BDBAs. | |

HTTR will restart without significant additional reinforcements due to its inherent safety features.